



NOT TO SCALE

NOTES:

1. COMPACT SOIL UNDER CONCRETE PAD OR SLAB TO NOT LESS THAN 98% MAXIMUM DRY DENSITY AS DETERMINED BY AASHTO T-180 SPECIFICATIONS.
2. CONCRETE SHALL BE 3000 PSI ($F'_c = 3000$ PSI).
3. CONTRACTOR SHALL PROVIDE A SCALED DRAWING SHOWING LOCATION OF PIPE SUPPORTS, DIMENSIONS OF SLAB AND SUPPORT TO THE TOWN OF JUPITER UTILITIES PRIOR TO CONSTRUCTION OF SLABS AND SUPPORTS.
4. CONCRETE COVERAGE SHALL BE 3" WHEN CONCRETE IS DIRECTLY AGAINST SOIL AND 2" WHEN CONCRETE IS EXPOSED TO WEATHER. ALL CORNERS SHALL HAVE A 3/4" CHAMFER.
5. REINFORCING STEEL SHALL BE DEFORMED, NEW BILLET STEEL, ASTM A-615 GRADE 60.

TYPICAL CONCRETE PIPE SUPPORT

JUPITER UTILITIES
CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED:
 12/2008

DRAWING No. W-29