



NOTES:

1. CONCRETE COLLAR MAY NOT BE REQUIRED IN PAVED AREAS IF PAVEMENT SURFACE IS FINISHED PRIOR TO CONDITIONAL FINAL INSPECTION AND VALVE BOX LID IS AT FINISHED GRADE.
2. WHEN VALVE IS DEEPER THAN 36" AN EXTENSION WILL BE REQUIRED TO BRING OPERATING NUT TO +/- 24" OF FINISHED GRADE. EXTENSION MUST BE SET SCREW TYPE AND ATTACHED TO OPERATING NUT.
3. TRACER WIRE SHALL BE USED ON NON-DUCTILE PIPE ONLY. TRACER WIRE MATERIAL SHALL BE COPPERHEAD INDUSTRIES, LLC OR APPROVED EQUAL, INSTALLATION AND TESTING SHALL BE IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS. TRACER WIRE MATERIAL SHALL BE AS FOLLOWS:
 - ROADWAY TRACER WIRE TEST STATION SHALL BE COPPERHEAD PART NUMBER RB14BTP OR APPROVED EQUAL.
 - TRACER WIRE TEST STATION SHALL BE COPPERHEAD PART NUMBER LD14BTP OR APPROVED EQUAL.
 - DIRECT BURY LUGS SHALL BE COPPERHEAD SNAKEBITE DRYCONN DIRECT BURY LUG AQUA OR APPROVED EQUAL.
 - TRACER WIRE SHALL BE COPPERHEAD INDUSTRIES, LLC PART NUMBER 1430-HS OR APPROVED EQUAL.
 - TRACER WIRE SHALL DEAD END WITH COPPERHEAD MAGNESIUM ANODE PART NUMBER ANO-1005 OR APPROVED EQUAL.
 - ABOVE GROUND TEST STATION SHALL BE COPPERHEAD INDUSTRIES, LLC PART NUMBER T1-B75 OR APPROVED EQUAL.

TYPICAL UNDERGROUND VALVE INSTALLATION

JUPITER UTILITIES
 CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED:
 06/2017
 DRAWING No. W-6