



NOTES:

1. INSTALL SERVICE/ARV DIRECTLY ABOVE CORPORATION STOP IF NOT LOCATED UNDER SIDEWALK OR ROAD.
2. ALL MATERIAL SHALL BE APPROVED BY THE TOWN OF JUPITER WATER UTILITIES PRIOR TO INSTALLATION.
3. TAPPING SADDLES:  
 FOR D.I.P., USE 1" DOUBLE STRAP TAP SADDLE WITH AWWA THREADS.  
 FOR C-900 PVC, USE FORD S-90 SERIES TAP SADDLE WITH AWWA THREADS.

WATER MAIN AIR RELEASE DETAIL

**JUPITER UTILITIES**  
**CONSTRUCTION STANDARDS AND DETAILS**

DATE APPROVED:  
 12/2021  
 DRAWING No. W-15