



NOTES:

1. POLY PIPE SHALL BE 2" PE3408 HDPE POLY TUBING, ASTM D-2737 FOR 200 PSI WITH PERMANENT SPECIFICATION MARKINGS. TUBING FITTINGS SHALL REQUIRE STAINLESS STEEL INSERTS.
2. ALL MATERIAL SHALL BE APPROVED BY THE TOWN OF JUPITER WATER UTILITIES PRIOR TO INSTALLATION.
3. ALL PIPING SHALL BE RESTRAINED PER TOWN OF JUPITER STANDARDS.
4. TRACER WIRE SHALL BE USED ON ALL NON-DUCTILE IRON WATER MAIN.
5. TRACER WIRE SHALL BE COPPERHEAD INDUSTRIES, LLC PART NUMBER 1430-HS OR APPROVED EQUAL.
6. TRACER WIRE SHALL DEAD END WITH COPPERHEAD MAGNESIUM ANODE PART NUMBER ANO-1005 OR APPROVED EQUAL.
7. DIRECT BURY LUGS SHALL BE COPPERHEAD SNAKEBITE DRYCONN DIRECT BURY LUG AQUA OR APPROVED EQUAL.

PERMANENT BLOWOFF - POST HYDRANT

JUPITER UTILITIES
CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED:	06/2017
DRAWING No.	W-18