



NOT TO SCALE

1. CONCRETE SLAB SHALL EXTEND A MINIMUM OF TWELVE INCHES (12") FROM THE OUTSIDE EDGES OF THE RISER PIPES.
2. ALL ABOVE GRADE PIPING SHALL BE PAINTED WITH SHERWIN WILLIAMS INDUSTRIAL ENAMEL, COLOR PERENNIAL GREEN.
3. ALL MATERIAL SHALL BE APPROVED BY THE TOWN OF JUPITER WATER UTILITIES PRIOR TO INSTALLATION.
4. ALL PIPING SHALL BE RESTRAINED PER TOWN OF JUPITER WATER UTILITIES STANDARDS.
5. PIPE AND METER SIZES SHALL BE DETERMINED BY THE ENGINEER OF RECORD AND FIRE MARSHAL.
6. TWO INCH (2") FIRE LINES WILL REQUIRE A 2 1/2" RPDA.
7. THE BACKFLOW PREVENTION DEVICE SHALL BE CERTIFIED BY THE UNIVERSITY OF SOUTHERN CALIFORNIA HYDRAULIC RESEARCH.

FIRE ONLY - REDUCED PRESSURE DETECTOR ASSEMBLY (2 1/2" - 10")

JUPITER UTILITIES
CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED:
09/2017
DRAWING No. W-27