



CONCRETE SIDEWALK SECTION DETAIL

NOTES:

1. SIDEWALK JOINTS SHALL BE IN ACCORDANCE WITH FDOT DESIGN STANDARDS (latest edition), TOPIC # 625-010-003, INDEX 310.
2. SIDEWALK TRUE MEASURE DEPTH THROUGH DRIVES/ENTRANCES SHALL BE:
5-1/2" FOR RESIDENTIAL DRIVEWAYS.
6" FOR COMMERCIAL TURNOUTS.
7-1/4" FOR INDUSTRIAL TURNOUTS.
3. CONCRETE STRENGTH SHALL BE 3000 PSI MINIMUM AND SHALL HAVE A MINIMUM 470 LB/CY OF PORTLAND CEMENT AND A MAXIMUM WATER TO CEMENT RATIO OF 0.55 LBS/LB.
4. CLEAR ZONE AS DEFINED IN FDOT "FLORIDA GREENBOOK".
5. SIDEWALK EDGE TO MATCH ROAD CROWN ELEVATION TO EXTENT PRACTICAL.
6. MINIMUM SIDEWALK THICKNESS SHALL BE 5-1/2 INCHES.



TOWN OF JUPITER
ENGINEERING DIVISION

210 MILITARY TRAIL
JUPITER, FLORIDA 33458
(561) 746-5134

Concrete Sidewalk

DETAIL AND REQUIREMENTS

DETAIL NUMBER

109a

Revised 20140527