



NOTES:

1. SIDEWALK JOINTS SHALL BE IN ACCORDANCE WITH FDOT DESIGN STANDARDS 2006, TOPIC # 625-010-003, INDEX 310.
2. SIDEWALK TRUE MEASURE DEPTH THROUGH DRIVES/ENTRANCES SHALL BE:
5-1/2" FOR RESIDENTIAL DRIVEWAYS.
6" FOR COMMERCIAL TURNOUTS.
7-1/4" FOR INDUSTRIAL TURNOUTS.
3. CONCRETE STRENGTH SHALL BE 3000 PSI MINIMUM AND SHALL HAVE A MINIMUM 470 LB/CY OF PORTLAND CEMENT AND A MAXIMUM WATER TO CEMENT RATIO OF 0.53 LBS/LB.
4. TOWN PROJECT BILLING FOR THIS CONFIGURATION SHALL BE LISTED UNDER PAY ITEM 522-2.
5. MINIMUM SIDEWALK THICKNESS SHALL BE 5-1/2 INCHES.



TOWN OF JUPITER
ENGINEERING DIVISION
 210 MILITARY TRAIL
 JUPITER, FLORIDA 33458
 (561) 746-5134

THICKENED EDGE SIDEWALK
 DETAIL AND REQUIREMENTS

V:\Engineering\Drawings\Details\2025\109c - Thickened Edge Sidewalk.dwg

DETAIL NUMBER

109c

Revised 20250414