



NOTES:

1. SIDEWALK JOINTS SHALL BE IN ACCORDANCE WITH FDOT DESIGN STANDARDS (latest edition), TOPIC # 625-010-003, INDEX 310.
2. SIDEWALK TRUE MEASURE DEPTH THROUGH DRIVES/ENTRANCES SHALL BE:
 - 2.1. 5-1/2" FOR RESIDENTIAL DRIVEWAYS.
 - 2.2. 6" FOR COMMERCIAL TURNOUTS.
 - 2.3. 7-1/4" FOR INDUSTRIAL TURNOUTS.
3. CONCRETE STRENGTH SHALL BE 3000 PSI MINIMUM AND SHALL HAVE A MINIMUM 470 LB/CY OF PORTLAND CEMENT AND A MAXIMUM WATER TO CEMENT RATIO OF 0.53 LBS/LB.
4. TOWN PROJECT BILLING FOR THIS CONFIGURATION SHALL BE LISTED UNDER PAY ITEM 522-2.
5. MINIMUM SIDEWALK THICKNESS SHALL BE 5-1/2 INCHES.
6. CROSS SLOPE TO BE MAXIMUM $\frac{3}{16}$ " PER FOOT (1.5%).



TOWN OF JUPITER
 ENGINEERING DIVISION
 210 MILITARY TRAIL
 JUPITER, FLORIDA 33458
 (561) 746-5134

RAISED SIDEWALK WITH 'D' CURB
 DETAIL AND REQUIREMENTS

V:\Engineering\Drawings\Details\2025\109d - Sidewalk n D curb.dwg

DETAIL NUMBER

109d

Revised 20250114