

TYPE OF USE	MIN. STRUCTURAL NUMBER
LIGHT DUTY VEHICLE PARKING (OFFICES) & DRIVEWAYS	2.0
INDUSTRIAL SITES & COMMERCIAL SITES	2.5
RESIDENTIAL & COLLECTOR STREETS	2.82
TRUCK PARKING, ARTERIAL STREETS, & INDUSTRIAL DRIVES	3.0

STRUCTURAL COEFFICIENTS FOR DIFFERENT PAVEMENT LAYERS		
FDOT SPECIFICATION SECTION	LAYER COEFFICIENT PER INCH	LAYER
331	0.44	<u>ASPHALT</u> TYPE SP
		<u>BASE</u>
200	0.18	CEMENTED COQUINA SHELL (LBR-100)
200	0.18	LIMEROCK (LBR-100)
200	0.18	RECYCLED CONCRETE AGREGATE (LBR-150)
200	0.18	SHELL (LBR-100)
200	0.18	SHELL-ROCK (LBR-100)
		<u>SUBGRADE</u>
160-2	0.08	TYPE B STABILIZED MINIMUM (LBR-40)

THICKNESS LIMITATIONS *			
SP 9.5	MINIMUM LIFT	1"	MAXIMUM LIFT 1½"
SP 12.5 **	MINIMUM LIFT	1½" *	MAXIMUM LIFT 3"

- * Except as approved by the Town Engineer
 ** SP 12.5 cannot be used as a final lift



TOWN OF JUPITER
 ENGINEERING DIVISION
 210 MILITARY TRAIL
 JUPITER, FLORIDA 33458
 (561) 746-5134

**MINIMUM PAVEMENT
 STRUCTURAL NUMBERS
 REQUIREMENTS**

V:\Engineering\Drawings\Details\2025\113 - StructuralNumber.dwg

DETAIL NUMBER

113

Revised 202111