



NOTES:

1. REFER TO ASTM C 936-82 AND SECTION 526, CONCRETE PAVERS IN THE T.O.J. SPECIFICATIONS FOR INSTALLATION REQUIREMENTS.
2. CONCRETE HEADER TO BE 3,000 PSI STANDARD MIX CONCRETE.
3. CONTRACTOR MAY CONSIDER USE OF MORTAR MIX WITH SAND BED TO STABILIZE THE PAVER SYSTEM & MINIMIZE SETTLEMENT.
4. HEADER CURB SHALL BE WHITE CONCRETE WITH GLASS BEADS SET IN SURFACE OF CONCRETE FINISH.
5. INTERLOCKING CONCRETE PAVERS SHALL BE "OLD CHICAGO" COLOR, 8"x4" SHAPE AND MANUFACTURED BY TREMRON CONCRETE INNOVATIONS OR APPROVED EQUAL.



TOWN OF JUPITER
ENGINEERING DIVISION
 210 MILITARY TRAIL
 JUPITER, FLORIDA 33458
 (561) 746-5134

**PAVER PEDESTRIAN CROSSING
 & SPECIAL HEADER CURB**
 DETAIL AND REQUIREMENTS

V:\Engineering\Drawings\Details\2025\117 - PaverSystem-Crosswalk.dwg

DETAIL NUMBER

117

Revised 20080703