



NOTES:

1. REFER TO ASTM C 936-82 AND SECTION 526, CONCRETE PAVERS IN THE T.O.J. SPECIFICATION FOR INSTALLATION REQUIREMENTS.
2. CONCRETE CURB TO BE 3,000 PSI STANDARD MIX CONCRETE.
3. INTERLOCKING CONCRETE PAVERS SHALL BE "OLD CHICAGO" COLOR, 8"x4" SHAPE AND MANUFACTURED BY TREMRON CONCRETE INNOVATIONS OR APPROVED EQUAL.



TOWN OF JUPITER
ENGINEERING DIVISION
 210 MILITARY TRAIL
 JUPITER, FLORIDA 33458
 (561) 746-5134

CONCRETE PAVER SYSTEM
for ROADWAY MEDIAN AREA
 DETAIL AND REQUIREMENTS

V:\Engineering\Drawings\Details\2025\118 - PaverSystem-median.dwg

DETAIL NUMBER

118

Revised 20080703