



NOTES:

1. ALL BACKFILL WILL REQUIRE COMPACTION TO SPECIFIED DENSITY, WITH DENSITY TESTS FOR ALL LIFTS (12" MAXIMUM LIFT).
2. S-W CUT -SPH-LT BEFORE EXCAVATING AND AS REQUIRED PRIOR TO NEW -SPH-LT PLACEMENT.
3. -SPH-LT SHALL BE ROLLED/COMPACTED TO A SMOOTH UNIFORM SURFACE, LEVEL WITH EXISTING/ADJOINING -SPH-LT.
4. MINIMUM -SPH-LT DENSITY SHALL BE 94% OF MAXIMUM DESIGN DENSITY FOR -SPH-LT MIX.



TOWN OF JUPITER
ENGINEERING DIVISION
 210 MILITARY TRAIL
 JUPITER, FLORIDA 33458
 (561) 746-5134

UTILITY TRENCH
PAVEMENT RESTORATION
 DETAIL AND REQUIREMENTS

V:\Engineering\Drawings\Details\2022\119 - Pavrest.dwg

DETAIL NUMBER

119

Revised 20220203